London Electronics Limited

Warren Court, Chicksands, Shefford, Bedfordshire SG17 5QB Tel +44(0)1462-850967 Fax +44(0)1462-850968 www.london-electronics.com help@london-electronics.com

DC digital panel meters . 3 1/2 and 4 1/2 digit DCI3 and DCI4 for Current DCV3 and DCV4 for Voltage

Connection details, scaling and general information

VERY IMPORTANT WARNINGS



You should carefully read all warnings and commence installation ONLY when you are satisfied that all warnings are adequately covered.



| ! Notes: | regulations, and all wiring shall be separated in accordance with IEC1010 |
|-------------|--|
| ! Notes: | Power supplies to this equipment must be anti-surge fused at 125mA for 230V supply, 250mA for 110V supply or 630mA for DC supplies in the range 12-30VDC |
| ! Notes: | Before installation, check that model number and supply voltage suit your application |
| ! Notes: | Lethal voltages may be present on the circuit board. Do not touch any circuitry when power is applied. |
| ! Notes: | This product is designed for Installation class II service |
| ! Notes: | This product is designed for use in Pollution-Degree 2 environments |
| ! Notes: | Use an insulated screwdriver when adjusting potentiometers and do not touch any circuitry |
| ! Notes: | Replace front cover when meter is unattended |
| ! Notes: | All adjustments to jumper settings or terminations must be made with power removed |
| ! Notes: | Ensure all screw terminals are tight before applying power. |

Safety FirstDon't make assumptions...... Always double check.
If in doubt, ask someone who is QUALIFIED to assist you in the subject.

TABLE OF CONTENTS

| 1) | Introduction |
|----|----------------------------------|
| 2) | Specifications |
| 3) | Panel Requirements + Connections |
| 4) | Alarm + Retransmission Option |
| 5) | Adjustments + Calibration |
| 6) | BCD O/P option |
| 7) | RS232 Output option |
| 8) | Declaration of Conformity |

IMPORTANT INTRODUCTORY NOTES

Thank you for choosing to use a London Electronics Ltd. product. We hope that you will be entirely satisfied with your purchase, and welcome any comments you may have which will help us to improve the ease of use, clarity of this manual, etc. for future shipments.

We invite you to write to us, free of charge, if posted in the United Kingdom, to:-

London Electronics Ltd.
Customer Services Department
FREEPOST SG334
SHEFFORD
Bedfordshire SG17 5BR

Alternatively you may send us a fax on **01462-850968** (international code +44) Or, telephone us on **01462-850967** (international code +44)

Or, send us an E-Mail to **meters@dial.pipex.com**

To enable us to provide a swift and accurate service, please be sure to provide the following information:

- 1) Full Model Number, including all options fitted.
- 2) Serial Number
- 3) DETAILED description of your difficulties, suggestions etc.
- 4) Input Range and Display range

This product is covered by a 2 year warranty, during which period we will put right or replace any meter found to be faulty through bad workmanship or materials. This warranty does not cover damage caused by misuse or accident.

IMPORTANT If the meter is a vital component in your process, you may wish to consider the purchase of a spare to cover the possible eventuality of a failure or accident, as we cannot guarantee instant repair or replacement.

We are constantly striving to improve our products and services, and as a result, changes to instruments do occur. Please ensure that this manual is kept safely for future reference, as future manuals, covering revised designs may no longer describe your product accurately.

We believe these instructions to be accurate, and the product to be competently designed and manufactured. We do not make any claims as to the suitability of this product for any particular application. The choice of product and responsibility for the choice lies with the User.

EQUIPMENT SPECIFICATIONS

Input Signals - all bipolar +/-.....200mV 2V 20V 200V 20mA 200mA 2A 5A 2mA Input Resistance...... 1M 1M 1M 1M 100R 10R 1R 0.1R 0.04R Resolution......1 in 2000 for DCV/I 3 meters, 1 in 20000 for DCV/I 4 meters CMRR......70 dB DC to 450 Hz. NMRR......56 dB 45 to 10000 Hz. Open Circuit Input Response.......Downscale Drive for all except 200mV, which will be indeterminate Decimal Point Selection.....Push-on Jumpers Accuracy......0.05% of reading Temperature stability.....50 ppm of range/C span and zero A/D Technique......Dual Slope integration Conversion Rate......2 1/2 conversions per second (every 400 mS) Integration Time......100 mS DisplayHigh brightness LED Digit Height......14.2mm 0.56" Digit Colour.....Red as standard, optionally green Excitation Supply.....none Accuracy..... Current Capacity..... **Power Supply** DC Supply......10 to 30 VDC as an option. Also 5V +/-5%. Current Consumption......Allow 8VA if all options fitted & excitation supply fully loaded. Mechanical Bezel Size......48mm high by 96mm wide Cutout Size......45 mm high by 92 mm wide Depth behind Panel.....125 mm Weight......550 grammes typically Case Material.....UL 94V0 rated black ABS **Environmental** Operating Temperature.....-20 to +50 degrees C Storage Temperature.....-40 to +85 degrees C Humidity......90% rh max. at 40 C, non condensing. Drive Capacity......4-20mA into loads 0 - 500 Ohms. 0-10 V into loads from 500 Ohms to Infinity Speed of Response......Standard = 500 milliseconds. Optionally available with 2 millisecond (option = FAST) Accuracy......0.05% of range Linearity................0.01% of range Alarm O/P Option Current Rating.......7 amperes, resistive. If driving inductive loads, MOV varistors are recommended Voltage Rating.....250VAC, 24VDC Speed of Response.....Standard = 15mS. Can provide solid state alarms with 5mS response speed. Hysteresis.....Typically 4 counts Annunciation......Red LED illuminates when relay de-energises Setting Method......Pushbutton allows alarm point to be viewed. Alter with coarse & fine potentiometers BCD O/P Option Format......Multiparallel, isolated, addressable tri-state. Presented on 50 way male IDC header Data Levels......12VDC up to 24VDC. Level is derived from power applied to BCD port Response speed.......Data available 5 milliSeconds after request. Data updated every 400mS Serial Data O/P Option Baud Rate.....Selectable 300, 600, 1200, 2400, 4800 or 9600 Addressing......32 addresses available Connections.....4 way detachable screw terminal connector

PANEL REQUIREMENTS



All wiring to this meter must be carried out in accordance with current IEC regulations Separation of all power carrying cables must be ensured in accordance with IEC 1010

Installation Class II Pollution degree 2




This meter is to be installed within a secure enclosure, to prevent accidental access by persons to the powered connections present on the meter's rear terminals.

CUTOUT DIMENSIONS

A hole 45 mm high and 92 mm wide, with minimal radius is required

Connections

Connector Specifications: [VDE Rated Voltage, group B insulation VAC = 380]-[VDE Rated Current = 8 Amperes.] [Vibration Immunity per VDE0611 <10g]-[Rated Number of mating cycles <100]-[Screw Clamp material/plating Steel/ZnCc] [Contact Spring material/plating CuSN/gal SnPb]-[Plug-in force, per pole is from 3 to 6 Newtons]-[Disconnect force per pole is from 4 to 7 Newtons]-[Screw clamp tightening torque recommended 0.5Nm]-[Solid wire csa between 0.13 to 1.5mm²] [Multistrand wire csa from 0.5 to 1.5mm²]-[AWG conductor range from 22 to 16]-[Gauge to DIN/EN50027 Size A1]




Please see appropriate section in this manual for connection details of BCD option or SERIAL output options. These options are mutually exclusive, and are not available with Analogue output or Trip output options.

AVOID DISAPPOINTMENT! Route **all** signals via individually screened cables. Do **not** mix input and output signals in the same screened cable. Earth the screens at a point as near to the meter as possible and do not earth the screen at the other end. Route all signal cables well away from power cables, relay switching cables and other sources of electrical noise.

ALARM & ANALOGUE O/P SETTINGS


This board is located below the display. You will only need to remove the board from the case if you wish to change the analogue output from 4-20mA to 0-10V. The board is supplied as 4-20mA default, unless you specifically ordered the unit to have 0-10V output.

To change trip action or adjust trip points, simply unclip the lens from the display, which will allow access to the jumpers and potentiometers.



ADJUSTMENTS & CALIBRATION


- 1) Ensure that the meter's power voltage settings are correct.
- 2) If the unit was ordered from us and calibration details were given at the time of ordering, you should not need to make any alterations to the meter's settings apart from applying input signals and checking the calibration.
- 3) If you wish to alter the meter's input range, or are unsure of what it has been set to, you will need to remove the circuit board from the case. To do so, remove the front bezel, the plug-in connectors and the screw(s) on the top/bottom rear surface of the case. The board may now be carefully withdrawn from the front aperture of the case.



- 4) When all selections have been made, place the assembly into its case, apply power and leave for 10 minutes to thermally stabilise.
- 5) Apply 0 % of input and adjust the ZERO pot to obtain 0% of display range.
- 6) Apply 100 % of input and adjust the SPAN pot for 100 % of display range.
- 7) Repeat steps 5) and 6) until no further adjustment is necessary
- 8) Apply 25%, 50% and 75% of input signal in turn, and check to ensure that the display responds accurately
- 9) Note your calibration settings on the meter's rating label for future reference


BCD-OUTPUT OPTION SETTINGS

This output option board is located below the display. You will only need to remove the board from the case if you wish to change the board's address. The board is supplied set to address 01 as default.




This option derives its data directly from the meter's A/D convertor. This data is updated every 400 milliseconds, but can be accessed within 5 milliseconds. The outputs and handshake lines are fully isolated from the meter to a level of 380 VAC. The option must be powered externally, typically from your PLC accessory supply.

The data output weighting of 1,2,4,8, ...10K corresponds to 4 1/2 digit meters. For 3 1.2 digit meters, divide the given values by 10. The addressing weighting will be identical for 3 1/2 and 4 1/2 digit



RS232 OUTPUT OPTION



Declaration of Conformity

Declaration Number : EMCAC Iss. 3 Issue Date : 21 April 1997

Products Covered: ACV/ACI-3 & 4 series

Title : AC Input Panel Meters

This is to confirm that the Products covered by this declaration have been designed and manufactured to meet the following specifications:

EN55022:1987 Conducted Emissions: Class B EN55022:1987 Radiated Emissions: Class B

IEC801-2:1984 Electro-Static Discharge Immunity: 8kV Air IEC801-3:1984 Radiated ElectroMagnetic field Immunity: 3V/m IEC801-4:1988 Fast Transient Immunity: AC 1kV, cable 0.5kV

Thus the products conform with the applicable sections of the following standards:

EN50081-1:1992 (normative) EN50082-1:1992 (normative)

and comply with the requirements of Council Directive 89/336/EEC relating to Electro-Magnetic Compatibility, & are designed to meet 72/23/EEC safety directive.

To confirm EMC compliance, representative models within the range have been independently tested and certified by MARCONI INSTRUMENTS EMC Department.

MARCONI CERTIFICATE # : TC95/0074D

MARCONI CERTIFICATE Issue #:1

MARCONI Certificate Issue Date :3 July 1995

Conditions

The meters are permitted a worst case error of 1% of A/D range during electro-magnetic disturbance, and must recover automatically when disturbance ceases without the need for human intervention, such as resetting, power-down etc.

The meters covered by this certificate must be installed in adherence to the following conditions:-

Signal cabling shall be routed separately to power carrying cabling (includes relay output wiring)
All signal cabling shall be screened. The screen shall only be terminated to the power earth terminal

This certificate applies only to meters carrying Serial Numbers 701001 or higher.

Declared as true and correct, for and on behalf of London Electronics Ltd. J.R. Lees -Director